

F9102 Boiler Replacement – Bid Questions and Answers #1

Question: Are we keeping all the hydraulics and only switching out motors? All else stays?

Answer: Yes

Question: Gas Piping, do the shut off values work

Answer: Yes

Question: What Size are the boiler supplies and returns

Answer: 2 ½ supplies and 2 ½ returns

Question: New domestic Water feeds for Boilers

Answer: No

Question: Will there be new Gas regulars on the boilers

Answer: No

Question: Will there be new Pot feeders installed

Answer: No

Question: New Gate values for supply and returns on boilers

Answer: No

Question: Are there any plans available

Answer: Please see the attached As Built Plans