

F9103 LED Lighting Replacement – Bid Questions and Answers #2

Question: Will the contractor be providing the new bulbs?

Answer: Yes

Question: What is the specification for wall packs (more sconce lighting)?

Answer: Please see Addendum 1 removing the wall packs from the Scope of Services.

Question: What is the specification for Pendant Lighting?

Answer: Bulb base type medium screw (E26)
 Bulb diameter 5 inch
 Bulb shape BR40
 Color temp 5000k
 Dimming

Question: Does state prevailing or Davis Bacon apply to this project

Answer: No

Question: Is there any BBU emergency lighting units in the fixtures

Answer: 194

Question: Does the buy American act apply to this project?

Answer: No