



Florida Department of Transportation

RON DESANTIS
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450

JARED W. PERDUE, P.E.
SECRETARY

March 26, 2025

ADDENDUM NO. 1

TO: PROSPECTIVE BIDDERS AND PLAN HOLDERS

PROPOSAL/CONTRACT ID: F9103

FINANCIAL PROJECT NUMBER(S): 454155-1-72-01

COUNTY(IES): Alachua

PROJECT NAME(S): State Materials Office LED Lighting Replacement

BIDS TO BE RECEIVED: April 3, 2025

SCOPE OF SERVICES REVISION

“Retrofit (93) exterior wall pack light fixture with an equivalent LED light bulb (daylight 5000k)” has been removed from the Scope of Services for this proposal. The revised Scope of Services is attached.

AMENDMENT NOTIFICATION

If you are a BID DOCUMENT HOLDER, please acknowledge receipt of this Addendum on the Bid Proposal page of the Bid Document.

Sincerely,

A handwritten signature in black ink, appearing to read "Phillip N. Davis".

Phillip N. Davis
Contracts Administration Office

PD:pd
Attached

EXHIBIT "A"

STATE MATERIALS OFFICE LED LIGHTING REPLACEMENT

SCOPE OF SERVICES

I. General Description

The Florida Department of Transportation is seeking bids for the remove and disposal of existing light bulb and ballast and retrofit of existing fixture to LED. The services under this contract will be located at the State Materials Office, 5007 NE 39th Ave., Gainesville, FL 32609.

II. Services

The Contractor will provide all labor, equipment, parts, and materials to perform the services mentioned below at an all-inclusive lump sum cost. The Contractor's scope shall include (but not limited to):

- Remove and disposal of all light bulbs and ballast in existing light fixtures.
- Retrofit existing (1250) 4-foot light fixtures with 2 new direct wire LED lights (daylight 5000k) and tombstone.
- Retrofit existing (25) 8-foot light fixtures with 2 new direct wire LED lights (daylight 5000k) and tombstone.
- Retrofit 12 existing pendant light with equivalent LED light (daylight 5000k).
- All existing lighting controls and timers are to remain operational, and all light fixtures have 277 volts.
- All work will be completed Monday – Friday between the hours of 8 am to 5 pm.
- The Contractor will be responsible for all permitting associated with project.
- The Contractor will be responsible disposal of all removed materials.
- Provide as-built drawings to the Owner.
- Provide warranty to the Owner for 1 year from the installation date.
- Work must be completed by June 20, 2025.
- The Contractor shall be responsible for final layouts, sizing, connection, etc. as required to furnish a complete and safe operating system.

III. Damages

- Contractor shall be responsible for damages to property caused by the Contractor.